



State of Ohio Environmental Protection Agency

P.O. Box 1049, 361 E. Broad Street
Columbus, Ohio 43266-1049
(614) 466-8565

Richard F. Celeste
Governor

Re: Ashtabula - Ashtabula County
Application No. 02-3177
Application for Sanitary Wastewater Treatment
Works
Received March 12, 1987
From A. C. Charnas and Associates

March 20, 1987

Acme Scrap Iron and Metal Company
2110 State Road
Ashtabula, Ohio 44004

Attention: Mr. Sam Simon

CERTIFIED MAIL

Enclosed is the Ohio EPA Permit to Install which will allow you to install the described source in the manner indicated in the permit. Because this permit contains several conditions and restrictions, I urge you to read it carefully.

As indicated on the permit, you are required to pay a permit fee as provided for by Section 3745.11 of the Ohio Revised Code and any rules established thereunder. The exact amount of this fee is indicated on page 1 of the Permit to Install. This amount must be remitted within fifteen (15) days of the effective date of the Permit to Install. Checks should be made payable to: Treasurer, State of Ohio and sent to Permits Bookkeeper, Ohio Environmental Protection Agency, 361 East Broad Street, Columbus, Ohio 43266-0558.

You are hereby notified that this action of the Director is final and may be appealed to the Environmental Board of Review pursuant to Section 3745.04 of the Ohio Revised Code by any person who was a party to this proceeding. The appeal must be in writing and set forth the action complained of and the grounds upon which the appeal is based. It must be filed with the Environmental Board of Review within thirty (30) days after notice of the Director's action. A copy of the appeal must be served on the Director of the Ohio Environmental Protection Agency and the Environmental Law Division of the Office of the Attorney General within three (3) days of filing with the Board. An appeal may be filed with the Environmental Board of Review at the following address:

Environmental Board of Review
250 East Town Street
Room 101
Columbus, Ohio 43266-0557

US EPA RECORDS CENTER REGION 5



401936

Acme Scrap Iron and Metal Company
March 20, 1987
Page 2

You should note that a general condition of your permit states that issuance of the permit does not relieve you of the duty of complying with all applicable federal, state and local laws, ordinances and regulations.

If you have any questions, please contact the Ohio EPA District Office to which you submitted your application.



Maan Osman, Manager
Water Quality Management Section
Div Water Pollution Control

MD/bs

Copy to Ashtabula County Health Department
" " Northeast District Office, Industrial Waste
" " Central Office, Industrial Waste

OHIO ENVIRONMENTAL PROTECTION AGENCY

Permit to Install

Application No. 02-3177

Applicant's Name: Acme Scrap Iron and Metal
Company

Permit Fee \$50.00

Address: 2110 State Road

City: Ashtabula

State: Ohio 44004

Telephone: (216) 998-2820


Description of Proposed Source: Sanitary Wastewater Treatment Works

Issuance Date: March 20, 1987

Effective Date: March 20, 1987

The above named entity is hereby granted a permit to install for the above described source pursuant to Chapter 3745-31 of the Ohio Administrative Code. Issuance of this permit does not constitute expressed or implied approval or agreement that, if constructed or modified in accordance with the plans included in the application, the above described source of environmental pollutants will operate in compliance with applicable State and Federal laws and regulations, and does not constitute expressed or implied assurance that if constructed or modified in accordance with those plans and specifications, the above described source of pollutants will be granted the necessary operating permits. This permit is granted subject to the following conditions attached hereto:

Ohio Environmental Protection Agency



Warren W. Tyler
Director
361 East Broad Street
Columbus, Ohio 43266-0149

Acme Scrap Iron and Metal Company
March 20, 1987
Page 2

This permit shall expire if construction has not been initiated by applicant within eighteen months of the effective date of this permit. By accepting this permit, applicant acknowledges that this eighteen month period shall not be considered or construed as extending or having any effect whatsoever on any compliance schedule or deadline set forth in any administrative or court order issued to or binding upon the permit applicant, and applicant shall abide by such compliance schedules or deadlines to avoid the initiation of additional legal action by the Ohio EPA.

The Director of the Ohio Environmental Protection Agency, or his authorized representatives, may enter upon the premises of the above named applicant during construction and operation at any reasonable time for the purpose of making inspections, conducting tests, examining records or reports pertaining to the construction, modification or installation of the above described source of environmental pollutants.

Issuance of this permit does not relieve you of the duty of complying with all applicable federal, state, and local laws, ordinances, and regulations.

This permit is conditioned upon payment of applicable fees as required by Section 3745.11 of the Ohio Revised Code, and shall be invalid unless the permit fee specified above has been paid in full to the Ohio EPA within fifteen days of issuance of this permit to install.

The proposed wastewater disposal system shall be constructed in strict accordance with the plans and application approved by the Director of the Ohio Environmental Protection Agency. There may be no deviation from these plans without the express, written approval of the agency. Any deviations from these plans or the above conditions may lead to such sanctions and penalties as provided under Ohio law. Approval of this plan and issuance of this permit does not constitute an assurance by Ohio Environmental Protection Agency that the proposed facilities will operate in compliance with all Ohio laws and regulations. Additional facilities shall be installed upon orders of the Ohio Environmental Protection Agency if the proposed sources are inadequate or cannot meet applicable standards.

This permit applies to a wastewater disposal system designed to serve an average daily hydraulic flow of no more than 600 gallons.

Filtering material used in filters shall comply with material specified in approved plans and specifications.

The treatment works shall be abandoned and the sanitary sewers connected to the public sanitary sewerage system whenever such system becomes available.

The appropriate district office of the Ohio Environmental Protection Agency shall be notified, in writing before the start of construction, as to (a) the construction starting date; (b) the construction completion date; and (c) the date the wastewater disposal system was placed into operation.